

2026 Water Testing Results - Ocean Crest Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room 1 Faucet	19690200-079CF26A	8/18/2026	ND
Room 2 Faucet	19690200-080CF26A	8/18/2026	4.63
Room 3 Faucet	19690200-081CF26A	8/18/2026	8.52
Room 4 Faucet	19690200-082CF26A	8/18/2026	1.33
Hallway by Storage - Drinking Fountain	19690200-083DW26A	8/18/2026	ND
Staff Room Faucet	19690200-084SF26A	8/18/2026	ND
Gym - Drinking Fountain	19690200-085DW26A	8/18/2026	ND
Gym Girls RR Faucet	19690200-086BF26A	8/18/2026	22.0
Gym Boys RR Faucet	19690200-087BF26A	8/18/2026	11.7
Boys RR by Entry Faucet	19690200-088BF26A	8/18/2026	ND
Girls RR by Entry Faucet	19690200-089BF26A	8/18/2026	11.5
Principal's Office Area RR Faucet	19690200-090BF26A	8/18/2026	1.25
Work Room - Staff Faucet	19690200-091SF26A	8/18/2026	ND
Principal's Office Area RR Faucet	19690200-092BF26A	8/18/2026	5.71
Room 6 Faucet	19690200-093CF26A	8/18/2026	ND
Staff RR by Library Faucet	19690200-094BF26A	8/18/2026	1.26
N Staff Faucet by Library	19690200-095SF26A	8/18/2026	11.6
Girls RR by Library Faucet	19690200-096BF26A	8/18/2026	11.7
Boys RR by Library Faucet	19690200-097BF26A	8/18/2026	4.51
Hallway by Lunchroom - Staff Faucet	19690200-098SF26A	8/18/2026	9.69
Lunchroom Kitchen Faucet	19690200-099KF26A	8/18/2026	ND
Lunchroom Kitchen Faucet	19690200-100KF26A	8/18/2026	2.53
Room 14 Faucet	19690200-101CF26A	8/18/2026	6.22
Hallway by Room 9 - Drinking Fountain	19690200-102DW26A	8/18/2026	ND
Room 13 Faucet	19690200-103CF26A	8/18/2026	64.1
Room 12 Faucet	19690200-104CF26A	8/18/2026	4.14
Boys Bathroom (Rooms 12-17 wing) Faucet	19690200-105BF26A	8/18/2026	1.21
Boys Bathroom (Rooms 12-17 wing) Faucet	19690200-106BF26A	8/18/2026	ND
Girls Bathroom (Rooms 12-17 wing) Faucet	19690200-107BF26A	8/18/2026	ND
Girls Bathroom (Rooms 12-17 wing) Faucet	19690200-108BF26A	8/18/2026	1.13
Room 18 Faucet	19690200-109CF26A	8/18/2026	3.30
Room 19 Faucet	19690200-110CF26A	8/18/2026	1.25
Nurse's RR Faucet (new)	19690200-118BF26A	8/18/2026	11.6
Counselor's Area - Sink (new)	19690200-119NS26A	8/18/2026	6.84
Room 17 Computer Lab Faucet (new)	19690200-120CF26A	8/18/2026	4.80
Room 20 Faucet (new)	19690200-121CF26A	8/18/2026	ND
Any fixture testing at or above the action level of 15 ppb has been immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up			
RETESTS : Will be conducting retests when faucets are ordered and replaced. Expected date			
11/01/2026			
ND = Non Detect - Lead level is below the lab's minimum reporting limit of 1.02 ppb			
Shaded results: red = at/above 15 ppb action level; orange = 10-14.99 ppb (EIS recommends addressing). Source: EIS Job No. 2026027, Alexin Analytical Laboratories.			